

**Summary of Substantive Changes
Between the 2008 and 2011 Editions of
ASTM D2661, “Acrylonitrile-Butadiene-Styrene (ABS)
Schedule 40 Plastic Drain, Waste, and Vent Pipe and Fittings”**

General: Provisions were added for particular sized reducing bushing wall thicknesses. The technical content of the standard was not changed significantly and there should be no impact on current listings.

Section A1.3, Reducing bushing wall thickness: *Reducing bushings of sizes 2 by 1-1/4 and 4 by 3 shall be permitted to have the socket wall thickness and spigot wall thickness below the minimum requirements defined in Table A1.1, but not less than 0.098 in (2.5 mm), provided the inner socket and outer spigot are reinforced by a minimum of four ribs. The thickness of the supporting ribs shall not be less than 0.098 in (2.5 mm)* was added

Table A1.1: Added equivalent SI dimensions to the table.