



**Summary of Substantive Changes  
between the 2004 and the 2010 editions of  
ASTM F493, “Solvent Cements for Chlorinated Poly(Vinyl Chloride)  
(CPVC) Plastic Pipe and Fittings”**

**Presented to the IAPMO Standards Review Committee on May 7, 2012**

**General:** The changes to this standard should not have an impact on currently listed products. The changes are:

- Removed a limitation on labeling location.

Section 10, Container Labeling and Marking:

Section 10.1.7: The following limitation on the location of labeling was removed;

*Lot number of batch on container ~~(not on closure or lid).~~*